

Number	P131103114	Replaces	P120801233
Issued	12-2013	Dated	03-2013
Valid until	03-2014		

Declaration of Conformity **DigiAlarm.net**


Based on inspections by Kiwa, the alarm transmission system referred to in this certificate, delivered by

ASB-Security B.V.

The service **DigiAlarm.net** complies with the requirements of SP1, SP2 SP3, SP4 and SP5 for single path systems, and DP1, DP2, DP3 and DP4 for dual path systems as subscribed in the NEN-EN50136-1:2012.

And can be used for all types of alarm messages such as

- Fire
- Intrusion,
- Acces control,
- Social alarm,
- Fault and status messages



Bouke Meekma
Director Kiwa N.V.

Page	2	Number	P131103114	Replaces	P120801233
		Issued	12-2013	Dated	03-2013
		Valid until	03-2014		

Alarm transmission

SYSTEM SPECIFICATION

The network service is supplied by; KPN Zakelijke Markt.
The network is owned by; KPN Zakelijke Markt.
Monitoring of the system is carried out by; ASB.
The Verification of Performance is carried out by; ASB.

PERFORMANCE

Based on the performed lot-by-lot inspection described in the inspection report P120801233 TdH the following performance have been found in the system;

- Transmission time complies with table 2 DP4 in NEN-EN50136-1:2012;
- Reporting time complies with table 3 DP4 in NEN-EN50136-1:2012;
- Availability of the network during the pilot complies with table 6 DP4 in NEN-EN50136-1:2012;
- Verification of Performance (VOP) during the pilot complies with chapter 7 of EN50136-1:2012.

The system meets the requirements for all types of transmission defined in the NEN-EN 50136-1:2012;

- SP1, SP2 SP3, SP4 and SP5 for single path systems, and
- DP1, DP2, DP3 and DP4 for dual path systems

as subscribed in the NEN-EN50136-1:2012.

TEST REPORTS USED TO VERIFY THIS CERTIFICATE:

- P120801233 TdH KPN: DigiAlarm Zakelijke doormelding
- 01-B012301025
- 02-B012301170
- 03-B012301152
- 04-B012306033
- 05-B012306091
- 06-B012302301